

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2
No. Hom (FS) (HQ)6-10/76-XI-Sml, NOC Dated 15/11/2015

Shimla-2
21/11/2015


TO WHOM IT MAY CONCERN

That the premises of Bhartiya Public Sr. Sec. School Joginder Nagar, Tehsil Joginder Nagar, Distt. Mandi. H.P. was inspected on 14.10.2015 with reference to their application No. Nil dated 04.10.2015 by the Incharge, Fire Post Joginder Nagar with regard to measures adopted for protection against fire and it has been reported/ recommended.


That the first aid fire fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed in his favour for two years (i.e. 18-11-2015 to 17-11-2017) subject to fulfillment of the following conditions:-


1. That each individual working on the above premises must be trained to handle/ operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintained the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire Precautionary measures be adopted in the consultation with local Fire Officer during annual day function or any other function in the School where temporary structures and Pandals are to be erected.


Chief Fire Officer,
Himachal Pradesh Shimla-2

To
The Principal,
Bhartiya Public Sr. Sec. School Joginder Nagar,
Tehsil Joginder Nagar, Distt. Mandi. H.P.


Principal
Bhartiya Public Sr. Sec. School
Joginder Nagar, Distt. Mandi (H.P.)
APP No. 23027, School Code : 170193


Principal
Bhartiya Public Sr. Sec. School
Joginder Nagar, Distt. Mandi (H.P.)
APP No. 23027, School Code : 170193